



CITY OF ATLANTA

Kasim Reed
Mayor

SUITE 1900
55 TRINITY AVENUE, SW
ATLANTA, GA 30303
(404) 330-6204 Fax: (404) 658-7705
Internet Home Page: www.atlantaga.gov

DEPARTMENT OF PROCUREMENT
Adam L. Smith, Esq., CPPO, CPPB, CPPM, CPP,
CIPC, CISCC, CIGPM
Chief Procurement Officer
asmith@atlantaga.gov

November 16, 2015

Dear Potential Proponents:

Re: FC-8471, Annual Contract for Milling, Resurfacing and Associated Activities

Attached is one (1) copy of **Addendum Number 2**, which is hereby made a part of the above-referenced project.

For additional information, please contact Ms. Jill Watkins, Contract Administrator, at (404) 865-8703 or by email at jewatkins@atlantaga.gov.

Sincerely,

Adam L. Smith

ALS/jew



ADDENDUM NO. 2

This Addendum No. 2 forms a part of the Request for Proposals and modifies the original solicitation package and any prior Addenda as noted below and is issued to incorporate the following:

1. **Revision:** Exhibit D – Bid Schedule and Pricing; Replace Exhibit D – Bid Schedule and Pricing in its entirety with **Attachment No. 2**.
2. **Revision:** Exhibit C – Special Conditions, SC-2 Work Hour Restrictions; Replace SC-2 in its entirety with the following:

SC-2 WORK HOUR RESTRICTIONS

No work will be performed on major thoroughfares during the AM and PM rush hours. Rush hour restrictions are between 6:00am and 9:00am & 4:30pm and 6:30pm. No work will be performed on any streets after 8:00pm unless otherwise designated by the City of Atlanta (“COA”). “Night time Work” will be defined as work occurring between the hours of 7pm and 7am and, as indicated must be sanctioned by the COA. Further, any work done during Night time hours must comply with the COA’s noise ordinance (which goes effect between the hours of 7pm and 7am during weekdays and 7pm and 9am on weekends) or those seeking to perform work during Night time hours must apply to the COA for a waiver.

3. Response to Questions (November 4, 2015): **Attachment No. 3**.

The last day for questions was Friday, October 23, 2015 at 1:00 P.M. EDT.

The Proposal due date has NOT been modified and Proposals are due on Thursday, November 19, 2015 and should be time stamped in no later than 2:00 P.M. EST and delivered to the address listed below:

Adam L. Smith, Esq., CPPO, CPPB, CPPM, CPP, CIPC, CISCC, CIGPM
Chief Procurement Officer
Department of Procurement
55 Trinity Avenue, S. W.
City Hall South, Suite 1900
Atlanta, Georgia 30303

****All other pertinent information is to remain unchanged****

Acknowledgment of Addendum No. 2

Proponents must sign below and return this form with Proposal to the Department of Procurement, 55 Trinity Avenue, City Hall South, Suite 1900, Atlanta, Georgia 30303 as acknowledgment of receipt of this Addendum.

This is to acknowledge receipt of Addendum No. 2 for **FC-8471, Annual Contract for Milling, Resurfacing and Associated Activities** on this the _____ day of _____, 20__.

Legal Company Name of Proponent

Signature of Authorized Representative

Printed Name

Title

Date

ATTACHMENT 2

EXHIBIT D - BID SCHEDULE AND PRICING **(Revised 11/16/15)**

FC- 8471, Annual Contract for Milling, Resurfacing & Associated Activities

SCHEDULE OF UNIT & LUMP SUM (LS) PRICES

All pavement markings shall be MUTCD-compliant

| ITEM CODE | DESCRIPTION | UNIT | BID UNIT PRICE | COST ESTIMATE | |
|-----------|---|------------------|----------------|---------------|--------|
| | | | | QUANTITY | AMOUNT |
| 150-10000 | TRAFFIC CONTROL | LS (Lump Sum) | | 1 | |
| 402-1802 | Recycle Asphalt Concrete Patching, Incl Bitum Mat & lime | TN (Ton) | | 2000 | |
| 402-3101 | TN. RECYC. ASPH. 9.5MM | TN | | 38,000 | |
| 402-3101A | SURCHARGE PLUS BASE CHARGE FOR NIGHT-TIME, WEEKEND or HOLIDAY WORK TN. 9.5MM | TN | | 4,000 | |
| 402-3130 | TN., RECYC. ASPH. 12.5MM | TN | | 5,000 | |
| 402-3130A | SURCHARGE PLUS BASE CHARGE FOR NIGHT-TIME, NIGHT-TIME, WEEKEND or HOLIDAY WORK TN. 12.5MM | TN | | 2,000 | |
| 413-1000 | G.L. TACK COAT | GL (Gallon) | | 40,000 | |
| 413-1000A | SURCHARGE PLUS BASE CHARGE FOR NIGHT-TIME, WEEKEND or HOLIDAY WORK G TACK COAT | GL | | 10,000 | |
| 611-8140 | ADJUSTMENTS TO MISC. ROADWAY STRUCTURES USING METAL OR POLY RISERS TO BE SUPPLIED BY THE CITY | EA (Each) | | 150 | |
| 611-8050 | MANHOLE COVERS | EA | | 500 | |

| ITEM CODE | DESCRIPTION | UNIT | BID UNIT PRICE | COST ESTIMATE | |
|-----------|--|----------------------------|----------------|---------------|--------|
| | | | | QUANTITY | AMOUNT |
| 432-5010A | S.Y. MILL ASPHALT 0-2" | SY (Square Yard) | | 400,000 | |
| 432-5010B | S.Y. MILL ASPHALT 2"-4" | SY | | 15,000 | |
| 432-5010C | SY MILL ASPHALT 4"-6" | SY | | 15,000 | |
| 432-5010D | SURCHARGE PLUS BASE CHARGE FOR NIGHT-TIME, WEEKEND or HOLIDAYS SY MILL ASPHALT 0-2" | SY | | 50,000 | |
| 432-5010E | SURCHARGE PLUS BASE CHARGE FOR NIGHT-TIME, WEEKEND or HOLIDAYS SY MILL ASPHALT 2"-4" | SY | | 50,000 | |
| 432-5010F | SURCHARGE PLUS BASE CHARGE FOR NIGHT-TIME, WEEKEND or HOLIDAYS SY MILL ASPHALT 4"-6" | SY | | 10,000 | |
| 652-2501 | SOLID TRAFFIC STRIPE 5" WHITE | LM (Linear Mile) | | 5 | |
| 652-2502 | SOLID TRAFFIC STRIPE 5" YELLOW | LM | | 2 | |
| 652-3501 | SKIP TRAFFIC STRIPE 5" WHITE | GLM (Gross Linear Mile) | | 4 | |
| 652-3502 | SKIP TRAFFIC STRIPE 5" YELLOW | GLM | | 1 | |
| 652-9001 | TRAFFIC STRIPE WHITE | SY | | 250 | |

| ITEM CODE | DESCRIPTION | UNIT | BID UNIT PRICE | COST ESTIMATE | |
|-----------|---------------------------------------|---------------------|----------------|---------------|--------|
| | | | | QUANTITY | AMOUNT |
| 652-9002 | TRAFFIC STRIPE YELLOW | SY | | 100 | |
| 653-0120 | THERMO MARKING ARROW TP-2 | EA | | 150 | |
| 653-0150 | THERMO MARKING ARROW TP-5 | EA | | 150 | |
| 653-0170 | THERMO MARKING ARROW TP-7 | EA | | 150 | |
| 653-0210 | THERMO MARKING ARROW TP-1 | EA | | 150 | |
| 653-1501 | THERMO SOLID STRIPE WHITE 5" | LF (Linear Feet) | | 46,600 | |
| 653-1502 | THERMO DOUBLE SOLID YELLOW CENTERLINE | LF | | 25,450 | |
| 653-1704 | THERMO SOLID STRIPE WHITE 24" | LF | | 2,000 | |
| 653-1804 | THERMO SOLID STRIPE WHITE 8" | LF | | 2,000 | |
| 653-1906 | THERMO SOLID STRIPE WHITE 6" | LF | | 10,000 | |

| ITEM CODE | DESCRIPTION | UNIT | BID UNIT PRICE | COST ESTIMATE | |
|-----------|--|------|----------------|---------------|--------|
| | | | | QUANTITY | AMOUNT |
| 653-3501 | THERMO SKIP STRIPE WHITE 5" | GLM | | 25,000 | |
| 653-6004 | THERMO TRAFFIC STRIPING WHITE | SY | | 100 | |
| 653-6006 | THERMO TRAFFIC STRIPING YELLOW | SY | | 100 | |
| COA - 001 | THERMO CROSSWALKS STRIPING WHITE | EA | | 250 | |
| COA - 002 | THERMO PARKING STALL STRIPING WHITE | EA | | 750 | |
| COA - 003 | LOOP DETECTOR REPAIR 6x6 | EA | | 40 | |
| COA - 004 | LOOP DETECTOR REPAIR 6x40 | EA | | 50 | |
| COA - 005 | LOOP DETECTOR REPAIR 6x50 | EA | | 50 | |
| COA - 006 | WHEEL CHAIR RAMPS 6" | SY | | 15,000 | |
| COA - 007 | SHARROWS | EA | | 40 | |
| COA - 008 | BICYCLE LANE SYMBOLS AND ARROWS | EA | | 39 | |

| ITEM CODE | DESCRIPTION | UNIT | BID UNIT PRICE | COST ESTIMATE | |
|-----------|---|---------------------|----------------|---------------|--------|
| | | | | QUANTITY | AMOUNT |
| COA - 009 | LEFT TURN ARROWS | EA | | 36 | |
| COA - 010 | 8' WIDE PIANO STYLE CROSSWALKS | LF | | 180 | |
| COA - 011 | SKIP YELLOW CENTERLINE | LF | | 3,550 | |
| 611-8000 | PHYSICAL ADJUSTMENTS CATCH BASIN | EA | | 100 | |
| 611-8040 | PHYSICAL ADJUSTMENTS DROP INLET | EA | | 100 | |
| 611-8060 | PHYSICAL ADJUSTMENTS MANHOLES | EA | | 500 | |
| 611-8140 | PHYSICAL ADJUSTMENTS WATER VALVES | EA | | 150 | |
| COA - 012 | GREEN BICYCLE BOX - COLORED ASPHALT | SF (Square Feet) | | 1,500 | |
| COA - 013 | TREE TRIMMING - 3 - 6" LIMB & HANGERS (Price/Tree) | EA | | 150 | |
| COA - 014 | CURBING REPAIRS - DEMOLITION AND REPLACEMENT OF STD 6" CONCRETE HEADER CURB | LF | | 14,000 | |
| COA - 015 | SIDEWALK REPAIRS - DEMOLITION AND REPLACEMENT OF STD 4" CONCRETE SIDEWALK | SY | | 7784 | |

| ITEM CODE | DESCRIPTION | UNIT | BID UNIT PRICE | COST ESTIMATE | |
|---|---|------|----------------|---------------|--------|
| | | | | QUANTITY | AMOUNT |
| 1. | BID SUBTOTAL (Base Bid) | | | | |
| 2. | 10% OF SUBTOTAL (Construction Contingency) | | | | |
| TOTAL BID (Sum of lines 1 and 2) | | | | | |

Total Base Bid Amount: \$ _____ that is _____
_____ (Words).

Construction Contingency \$ _____ that is _____
_____ (Words).

Total Bid Price \$ _____ that is _____
_____ (Words).

ATTACHMENT 3
RESPONSE TO QUESTIONS (3 Questions)

ATTACHMENT NO. 3
Response to Questions (3 Questions)

1. Question

Please send a detail for the green bicycle box, as there is no way to make green asphalt.

Answer

The green bicycle box can be a pavement marking (using a color safe color pavement marking and anti-skid surfacing). For all pavement markings it is recommended to use thermoplastic (MMA or equivalent) with an anti-skid surfacing to minimize loss of traction for bicyclists.

The recommended green is:

Color combination values:

X: .03284 y: .5053 Y: 26.81 L: 58.85 a: -38.31 b: 42.32

CMYK translation:

C: 71.4% M: 15.41% Y: 100% K: 1.83%

A comparable color is also acceptable.

2. Question

Will the surcharge for Weekend and Holiday work be applicable for Night Work that might have to be performed at night?

Answer

Yes. See Addendum No. 2, Item Nos. 1 and 2.

3. Question

Is it possible to add a pay item for physical adjustments of manholes and water valves?

Answer

Yes. See Addendum No. 2, Item No. 1.