

Addendum 1

December 10, 2015

Project: Folk Art Park Enhancement Project Atlanta, Georgia

Project Number: GA DOT Project CSTEE-0009-00(048)
City of Atlanta, Owner

The following questions were asked regarding the Project Documents

- 1) **Section 03 0100 – 3.02 C.3.a Cleaning Existing Concrete and Stucco – question maximum 100 psi as a typo.**

Answer: This is not a typo; some artwork pieces are fragile and cleaning must be gentle. Each individual art piece should be evaluated on a case by case basis to determine if a higher pressure could be used; approval from the Art Conservator must be obtained prior to proceeding.

- 2) **Section 03 0100 – 3.02 C.4.a and C.5.1 Cleaning Existing Concrete and Stucco – question maximum 400 psi as a typo.**

Answer: This is not a typo; some artwork pieces are fragile and cleaning must be gentle. Each individual art piece should be evaluated on a case by case basis to determine if a higher pressure could be used; approval from the Art Conservator must be obtained prior to proceeding.

- 3) **Section 09 0691-1 Preparation and Finishes Schedule:**

1. Zone A, Quilt Traditions, Floor Quilt: clarify why no paint color is shown in the far right column of spreadsheet.

Answer: The existing Floor Quilt will be cleaned but not repainted.

2. Zone H2, Item P9, Animals, Tim Lewis: clarify why are only three sculpture bases are show to be repaired and not the actual sculptures.

Answer: there are three sculptures that have integral color stain in the concrete and should be included in the concrete repair work.

END OF ADDENDUM #1