



CITY OF ATLANTA

Kasim Reed
Mayor

SUITE 1900
55 TRINITY AVENUE, SW
ATLANTA, GA 30303
(404) 330-6204 Fax: (404) 658-7705
Internet Home Page: www.atlantaga.gov

DEPARTMENT OF PROCUREMENT
Adam L. Smith, Esq., CPPO, CPPB, CPPM, CPP,
CIPC, CISCC, CIGPM, CPPC
Chief Procurement Officer
asmith@atlantaga.gov

March 14, 2016

Dear Potential Bidder:

Re: FC-8476, Installation of Traffic Calming Devices

Attached is one (1) copy of **Addendum Number 1**, which is hereby made a part of the above-referenced solicitation.

For additional information, please contact Mrs. Teresa Slayton, Contracting Officer, CPPB, CPP, CPPM, GCPM, GCPA at (404) 865-8757 or by email at tslayton@atlantaga.gov.

Sincerely,

Adam L. Smith

ALS/ts

cc: Mr. Richard Mendoza
Mr. Rick Toca
Ms. Contena Alexander



FC-8476, Installation of Traffic Calming Devices

Addendum No.1

March 14, 2016

Page 2

ADDENDUM NO. 1

This Addendum No. 1 forms a part of the Invitation to Bid and modifies the original solicitation package and any prior addenda as noted below and is issued to incorporate the following:

- **Revised Due Date:**
The revised due date is Friday, March 18, 2016 at 2:00 P.M. EDT.
- **Questions and Answers:**
A total of six (6) questions and answers are attached hereto as Attachment No. 1.
- **Speed Table Installation List:**
The revised Speed Table Installation List is attached hereto as Attachment No. 1.
- **Figure 2. Speed Table/Hump Diagram:**
The Figure 2. Speed Table/Hump Diagram is attached hereto as Attachment No. 1.

Addendum No. 1 for **FC-8476, Installation of Traffic Calming Devices** is available for pick-up in the Plan Room: City Hall, 55 Trinity Avenue, Suite 1900 (1st Floor) City Hall South, Atlanta, Georgia 30303.

The Bid due date HAS been modified and Bids are due on Friday, March 18, 2016 and should be time stamped in no later than 2:00 P.M. EDT and delivered to the address listed below:

Adam L. Smith, Esq., CPPO, CPPB, CPPM, CPP,
CIPC, CISCC, CIGPM, CPPC
Chief Procurement Officer
Department of Procurement
55 Trinity Avenue, S. W.
City Hall South, Suite 1900
Atlanta, Georgia 30303

****All other pertinent information is to remain unchanged****



FC-8476, Installation of Traffic Calming Devices

Addendum No.1

March 14, 2016

Page 3

Acknowledgment of Addendum No. 1

Bidders must sign below and return this form with Bid to the Department of Procurement, 55 Trinity Avenue, City Hall South, Suite 1900, Atlanta, Georgia 30303 as acknowledgment of receipt of this Addendum.

This is to acknowledge receipt of Addendum No. 1 for **FC-8476, Installation of Traffic Calming Devices** on this the _____ day of _____, 20__.

Legal Company Name of Bidder

Signature of Authorized Representative

Printed Name

Title

Date



ATTACHMENT I

Question 1:

Why is a GA Utility Contractors License required for this ITB? GDOT does not require paving contractors to have this certification.

Answer: The Utility Contractor's License is not required for this project due to the work being performed is on the roadway's surface and does not require digging. However, the Contractor is required to contact 811 for the utility location where speed cushions will be installed and secured. The Contractor will be responsible for any subsurface damages.

Question 2:

Per Specification's Section 2.4, states use asphalt concrete "E" mix, can it be changed to "G" mix so that there is a smooth transition to the road?

Answer: The City recommends using a mix "G" instead of "E".

Question 3:

Per Specification's Section item 2.7 *"The Contractor shall install four (4) preformed thermoplastic, hot tape "shark teeth" two (2) in each direction of travel. They shall have a '3 base and be 5' tall and 125 mill thick, ester rosin, pre-beaded and retro-reflective (Fig. 2). There is no figure 2 to go along with the directions.*

Answer: Figure 2 is attached.

Question 4:

The Split Speed Cushion specification (per-fabricated modules) states, they must be pre-approved by the Fire Department. Has the Fire Department pre-approved any? If so, what are the areas? Also, what types have the City looked at so all contractors can bid on the same item?

Answer: This statement pertains only to the gap width, but not actual speed cushion installation. Gaps will be adjusted by the Managing Engineer based on the feedback from the Fire Department on the field.

Question 5:

During the pre-bid meeting, it was stated that there was a site visit, when and where will that site visit be scheduled?

Answer: The City's personnel are available Monday through Friday, 8:15 A.M. to 5 P.M. All interested bidders must contact the Contracting Officer to schedule a site visit.

Question 6:

Can the City provide more insight on the Speed Cushion be given, looking at the Traffic Logix website it looks like all of the information was taken from there, if so have they been approved by the Fire Department?

Answer: Traffic Logix information was used for information purpose only. Contractors are not required to use Traffic Logix products. Statement about Fire Department approval pertains only to the gap width but not actual speed cushion installation. Gaps will be adjusted by the City engineer based on the feedback from the Fire Department on the field. The Fire Department did not approve or disapprove any cushions.




FC-8476, Installation of Traffic Calming Devices Speed Table Installation List

Project Name	Beginning @	Ending @	Council District (CD)	Neighborhood Planning Unit (NPU)	Approximate Width (ft)	Approximate No. of Speed Tables
Cottage Grove Avenue, SE	Oakview Road	4th Avenue	5	O	28	4
Redland Road, NW	Collier Road	Dellwood Drive	8	C	28	1
Charter Oak Drive, SW	Bakers Ferry Road	Wisteria Lane	10	H	29	3
Ridgecrest Road, NE	Dekalb Avenue	city-limit	5	N	32	2
Flagler Avenue, NE	Montgomery Ferry Drive	Rock Spring Road	6	F	24	3
Holderness Street, SW	Westview Drive	Sells Avenue	4	T	30	2
Sandcreek Drive, SW	Campbellton Road	end-of-street	11	P	31	4
Dodd Avenue, SW	Pryor Street	Cooper Street	4	V	30	2
Wilson Mill Road, SW	Boulder Park Drive	Wildwood Lake Drive	10	H	32	2
Sandspring Drive, SW	Sandcreek Drive	end-of-street	11	P	31	4
Willis Mill Road, SW	M.L. King Jr Drive	Larchwood Drive	10	I	26	3
Vickers Street, SE	Moreland Avenue	Woodland Avenue	1	W	30	2
Whitehall Terrace, SW	Glenn Street	Fulton Street	4	V	30	3
Whittington Drive	Wieuca Road	Ivy Road	7	B	30	3
Rock Spring Road, NE	Piedmont Ave	Monroe Drive	6	F	30	5
Woodland Hills Avenue, NW	Collier Road	Harper Street	9	D	29	4
Acorn Avenue, NE	Lindbergh Drive	East Wesley Road	7	B	29	4
North Stratford Road, NE	Wieuca Road	Longleaf Drive	7	B	30	5


Note: This list of streets is not inclusive of streets that may be added to the list in the near future. Speed cushions on Woodland Hills Ave may be installed by City crews as a pilot project prior to approval of this contract.

Figure 2


- NOTES: 1 TAPER SIDES DOWN TO THE EDGE OF GUTTER LINE, OR 12" PAST EDGE OF PAVEMENT.
 2. SECURE BLOCKS TO EXISTING PAVEMENT WITH TACK.



TOP VIEW
N.T.S.



SECTION A-A
N.T.S.



CROSS SECTION
N.T.S.

THIS DETAIL WAS TAKEN FROM THE CITY OF ATLANTA'S WEBSITE. IT MAY HAVE BEEN MODIFIED AND SHOULD BE REVIEWED THOROUGHLY.

City of Atlanta



STANDARD DETAILS

SPEED HUMP

REV.
 DATE: SEPT 2011
 ORIG. DATE: NOV 2004
 SCALE: N.T.S.

DETAIL NO. TR-G_SH001